



301 N.W. Flagler Avenue • Stuart, Florida 34994
(772) 692-4344 • Fax: (772) 692-4341 • E-mail: captecinfo@gocaptec.com

ADDENDUM No. 2 ISSUED August 9, 2010

TOWN OF SEWALL'S POINT

- Schedule A: Continuing Services for Maintenance Services Relative to Roadway/Parking/Stormwater Improvements
- Schedule B: Disaster Recovery - First 72 Hours (Emergency)
- Schedule C: Disaster Recovery - Vegetative & Storm Debris Removal
- Schedule D: Pavement Overlay 2010/2011
- Schedule E: Micro-Surfacing/Crack Sealant

This ADDENDUM has been issued to all Bidders in order to clarify contract document intent.

The following clarifications are issued in response to questions submitted at or subsequent to the August 4, 2010 pre-bid meeting.

In reference to *Schedule D - Pavement Overlay*:

Question 1:

What is the material specification on the Geotex Fabric?

ANSWER 1:

See attachment.

Question 2:

Will striping the overlay be required to be part of this bid cost?

ANSWER 2:

In Schedule D, there is no striping; the Town will contract with a separate company.

Question 3:

What specific testing is required for an overlay operation? Full time onsite asphalt inspector or material mix design only?


ANSWER 3:

Relative to replacement of curb, densities will be needed. Material mix design is required for the asphalt; therefore no full-time on-site inspector is needed.

****PLEASE ALSO NOTE THAT THE TOWN HAS POSTPONED THE BID DUE DATE TO THURSDAY, AUGUST 12, 2010 AT 3:00PM, AT WHICH TIME THE BIDS WILL BE OPENED AND READ ALOUD****

This **ADDENDUM No. 2** shall be considered part of the Request for Bid documents previously released.

To acknowledge receipt of this **ADDENDUM No. 2**, please sign in the space provided below and **return a copy of this ADDENDUM with the proposal submitted in response to this solicitation**. If there are any questions, please contact Joseph W. Capra at (772) 692-4344.



Joseph W. Capra, P.E.
Project Manager

ADDENDUM No. 2 was received on _____ by _____.
Date Signature

Printed Name and Title

Company Name

JWC/gc
P:\000\023\023.103 - 2010 Debris Emgy Construction Contract\Final Bid Documents\Addendum 2-080910.doc

PRODUCT DATA SHEET

PETROMAT® 4599

PETROMAT 4599 is a nonwoven polypropylene geotextile produced by Propex, and will meet the following Minimum Average Roll Values (MARV) when tested in accordance with the methods listed below.

PETROMAT 4599 is used as a moisture barrier and stress absorbing interlayer beneath asphalt overlay or a chip seal.

PETROMAT 4599 conforms to the property values listed below¹. Propex performs internal Manufacturing Quality Control (MQC) tests that have been accredited by the Geosynthetic Accreditation Institute – Laboratory Accreditation Program (GAI-LAP).

PROPERTY	TEST METHOD	MARV ²	
		ENGLISH	METRIC
Physical			
Mass/Unit Area	ASTM D-5261	3.6 oz/yd ²	122 g/m ²
Mechanical			
Grab Tensile Strength	ASTM D-4632	90 lbs	400 N
Grab Elongation	ASTM D-4632	50%	50%
Mullen Burst	ASTM D-3786	180 psi	1240 kPa
Asphalt Retention	ASTM D-6140	0.20 gal/yd ²	0.90 l/m ²
Endurance			
UV Resistance (% retained @150 hrs)	ASTM D-4355	70%	70%

NOTES:

1. The property values listed above are effective 08/2006 and are subject to change without notice.
2. Values reported in weaker principal direction. Minimum average roll values (MARV) are calculated as the typical minus two standard deviations. Statistically, it yields a 97.7% degree of confidence that any samples taken from quality assurance testing will exceed the value reported.



Propex Inc.
6025 Lee Highway, Suite 425
PO Box 22788
Chattanooga, TN 37422

PH: 423 899 0444
PH: 800 621 1273
FAX: 423 899 7619
www.geotextile.com

Geotex®, Landlok®, Pyramat®, X3®, SuperGro®, Petromat® and Petrotac® are registered trademarks of Propex Inc. THIS PUBLICATION SHOULD NOT BE CONSTRUED AS ENGINEERING ADVICE. WHILE INFORMATION CONTAINED IN THIS PUBLICATION IS ACCURATE TO THE BEST OF OUR KNOWLEDGE, PROPEX DOES NOT WARRANT ITS ACCURACY OR COMPLETENESS. THE ULTIMATE CUSTOMER AND USER OF THE PRODUCTS SHOULD ASSUME SOLE RESPONSIBILITY FOR THE FINAL DETERMINATION OF THE SUITABILITY OF THE INFORMATION AND THE PRODUCTS FOR THE CONTEMPLATED AND ACTUAL USE. THE ONLY WARRANTY MADE BY PROPEX FOR ITS PRODUCTS IS SET FORTH IN OUR PRODUCT DATA SHEETS FOR THE PRODUCT, OR SUCH OTHER WRITTEN WARRANTY AS MAY BE AGREED BY PROPEX AND INDIVIDUAL CUSTOMERS. PROPEX SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING WITHOUT LIMITATION, WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, OR ARISING FROM PROVISION OF SAMPLES, A COURSE OF DEALING OR USAGE OF TRADE.